



THE NATIONAL BOARD
OF BOILER AND PRESSURE VESSEL INSPECTORS

January 9, 2020

Mr. Brad Mercadal
ValvTechnologies, Incorporated
5904 Bingle Road
Houston, TX 77092

SUBJECT: Scope Change, Valve Type: Z*-105***8***
NB Capacity Certification: VLC-M59105

Dear Mr. Mercadal:

Enclosed please find a copy of test number 51081S which was performed at the National Board Testing Laboratory on January 7, 2020, for the purpose of adding a new inlet and outlet configuration to the subject capacity certification. This test was performed in accordance with paragraph PG-69.6 of Section I of the ASME Code with steam as the test medium.

The valve had a measured slope of **41.21 PPH/PSIA**. This slope is within the required range of $\pm 5\%$ of the average slope of **42.29 PPH/PSIA** established during provisional testing.

ValvTechnologies, Incorporated has successfully completed testing to add the new inlet and outlet configuration to the subject capacity certification.

Yours truly,

Austin Peck
Manager of Pressure Relief Testing Laboratory

ENCLOSURE(S)

FILE: <200109 VLC-M59105 SCOPE CHANGE TESTING PASS>

National Board Testing Laboratory

Steam Test - Timed Weight Method

Valve ID Data		Revision 4	apps\Labview Programs\DATA\Steam Tests\51081S.xls
1	Test Number	51081S	
2	Test Sponsor	ValvTechnologies, Incorporated	
3	Company Type	Manufacturer	Houston, TX
4	Test Date	1/7/2020	VLC
5	Valve Type	Z_105	
6	Manufacturer	ValvTechnologies, Incorporated	
7	Cap. Cert. ID No.	59105	
8	Set Pressure		
9	Inlet Size	1 1/2 FI	
10	Outlet Size	2 FI	
11	Stamped Capacity	Not Stamped	
12	Code Section	I	
13	Serial Number	XQJ01	
14	Date Code		
Operational Data and Measured Dimensions			
15	Warn Pressure		psig
16	Set Pressure		psig
17	Reset Set Pressure		psig
18	Blowdown		psi
19	Reset Blowdown		psi
20	Bore Diameter	1.055	inch
21	Lift		inch
Measured Data			
22	Flow Area	0.87417	in ²
23	Vessel Pressure	125.0	psig
24	P _b	14.25	psia
25	Calorimeter Temp.	293.5	°F
26	Time of Run	4.0	minutes
27	Weight	373.4	lbm
28	Leakage	149.3	PPH
Calculated Data			
29			
30	Vessel Pressure	139.3	psia
31	Enthalpy, calorimeter	1,189.7	BTU/lbm
32	Saturation Temp., Vessel	352.6	°F
33	Saturation Volume, Vessel	3.2364	ft ³ /lbm
34	Steam Quality, Vessel	99.6	%
35	Vessel Temp. (Theoretical)	352.6	°F
36	Vessel Volume	3.2233	ft ³ /lbm
37	Degrees Superheat	N/A	°F
38	Capacity Correction	0.9980	
39	Measured Capacity	5739.0	PPH
40	Slope	41.213	PPH/PSIA
41	Coefficient	0.91544	
42	Rated Capacity For Measured Set	N/A	PPH
43			
44			in ²

National Board Testing Laboratory

Steam Test - Timed Weight Method: Test Summary

Test Summary for test 51081S:

V:\apps\Labview Programs\DATA\Steam Tests\S.xls

1. Valve tested for Scope Change as a Manufacturer.
2. Measured slope = 41.2 PPH/psia. -5% slope from original provisional testing = 40.2 PPH/psia. Slope is within acceptance band.

I certify that the data on the attached test data sheets was obtained under my supervision in accordance with the provisions of ASME PTC 25, the applicable sections of the ASME Boiler and Pressure Vessel Code, and the National Board Testing Laboratory Quality Control Manual. To the best of my knowledge and belief the objects tested were of the same type and design as indicated.


Authorized Observer: Robert Viers


Date

Test Personnel

Company Representatives

Robert Viers
Steve Bowman