



**THE
NATIONAL
BOARD**

OF BOILER AND
PRESSURE VESSEL
INSPECTORS

June 14, 2012

Mr. Stephen Smith
Valvtechnologies, Incorporated
5904 Bingle Rd
Houston, TX 77092

**Subject: Renewal of Capacity Certification, Valve Type ERV 3-1/16" Bore
(NB Cap. Cert ID No.: VLC-M59037)**

Dear Mr. Smith,

We have reviewed the application for renewal of capacity certification for the subject valve type dated June 9, 2012. As noted in the last recertification of this design, the maximum set pressure accepted is based upon the Class 600 flanges as shown on the drawing. Since the flow path is unchanged and no functional testing of power operated valves is required, all requirements for recertification have been met.

Valvtechnologies, Incorporated is hereby granted capacity certification and authorization to apply the "NB" mark to the valve type listed in the scope of certification. This authorization is valid for the above location and only while the organization holds a current ASME "V" Certificate of Authorization and is fully implementing its quality system as accepted by the National Board.

SCOPE OF CERTIFICATION

VALVE TYPE: ERV 3-1/16" Bore

Organization Type: Manufacturer

**Certified Rating Value: Slope = 312.2 PPH/PSIA
Size: 3" x 3-1/16" bore x 3"
Pressure Range: 15 psi through Class 600**

Certification Expiration Date: June 9, 2018

1055 GRUPPER AVE.
COLUMBUS, OHIO
43229-1183
U.S.A.
614.888.8320

EXECUTIVE
Fax 614.888.0750

TECHNICAL
Fax 614.847.1828

PRESSURE RELIEF DEPT.
Fax 614.848.3474

ORDER DEPARTMENT
Fax 614.847.1147

TRAINING DEPARTMENT
Fax 614.847.5542

EMAIL
information@nationalboard.org

WEB SITE
nationalboard.org

Yours truly,

Joseph F. Ball, P. E.

Director, Pressure Relief Department

REF: VLC-M59037 ren6-12.docx