



14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario
Canada M8X 2X4
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

July 26, 2013

Mr. DAVID COON
VALVTECHNOLOGIES INC
5904 BINGLE
HOUSTON TX 77092
US

Service Request Type: BPV-Nuclear Fitting Reg
Service Request No.: 1079066
Your Reference No.: 121551
Registered to: VALVTECHNOLOGIES INC

Dear Mr. DAVID COON,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN No.: NFC-2-5926.5
Main Design No.: 121551-001 Rev.2
Expiry Date: N/A

Please be advised that a valid quality control system must be maintained for the nuclear fitting registration to remain valid.

The stamped copy of the approved registration and the invoice are mailed separately. Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Brian Chan, P.Eng.
Mechanical Engineer – Nuclear, BPV
Tel. : 416-734-3427
Fax : 416-231-6183
Email : BChan@tssa.org



TECHNICAL STANDARDS & SAFETY AUTHORITY
 14th Floor, Centre Tower
 3300 Bloor Street West
 Toronto, Ontario
 Canada M8X 2X4

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below

STATUTORY DECLARATION Registration of Fittings

I, David R. Coon, Nuclear Quality Assurance Manager
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of VALVtechnologies, LLC
(Name of Manufacturer)

Located at 5904 Bingle Road, Houston, Texas 77092 713-715-5577 713-860-0499
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of ASME Section III NC 2007 Edition, No Addenda

(Title of recognized North American Standard)
 which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with _____ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ASME NCA-4000 which has been verified by the following authority, American Society of Mechanical Engineers

The items covered by this declaration, for which I seek registration, are category C type fittings. In support of this application, the following information and/or test data are attached as follows:
valve data sheet and technical specification. Design report, and drawing

(drawings, calculations, test reports, etc.)

Declared before me at 5904 Bingle Road in the State of Texas
 the 05th day of April AD 2013.



Commissioner for Oaths:
Audrey Ramsey
(Printed name)
Audrey Ramsey
(Signature)

Technical Standards and Safety Authority
D.R. Coon
(Signature of Declarer)
Boilers and Pressure Vessels Safety Program

FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category NFC

CRN: N285-0 NFC-2-5926.5

Registered by: Poran Chan

Dated: 2013-07-26

NOTE: This registration expires on N/A

REGISTERED

CRN: NFC-2-5926.5
 Signed: Poran Chan
 Date: 2013-07-26

Notes:
 1. Bruce Power B-SPEC-04940-00004 Rev. 001
 B-SPEC-01370-00001 Rev. 001
 B-PES-000068506 Rev. 001

2. Drawing no. 121551-021 Rev. 2
 Design report no. 19228-001-QC-02 Rev. 2



NPT

CERTIFICATE OF AUTHORIZATION

The named company is authorized by the American Society of Mechanical Engineers (ASME) for the scope of activity shown below in accordance with the applicable rules of the ASME Boiler and Pressure Vessel Code. The use of the certification mark and the authority granted by this Certificate of Authorization are subject to the provisions of the agreement set forth in the application. Any construction stamped with this certification mark shall have been built strictly in accordance with the provisions of the ASME Boiler and Pressure Vessel Code.

COMPANY:

Valvtechnologies, Inc
5904 Bingle Road
Houston, Texas 77092

SCOPE:

Class 1, 2 & 3 fabrication with design responsibility for appurtenances at the above location only

AUTHORIZED: March 23, 2012
EXPIRES: March 6, 2015
CERTIFICATE NUMBER: N-3329



A handwritten signature in black ink, appearing to read 'William J. ...'.

Vice President, Conformity Assessment

A handwritten signature in black ink, appearing to read 'Paul D. ...'.



Director, Conformity Assessment



CUSTOMER: BRUCE POWER L.P.
P.O. NO.: 00176474 REV 001
BRUCE A & B DRAIN VALVES

NOTES:

1. VALVE DESIGNED IN ACCORDANCE WITH:
 - A. ASME SECTION III, DIV I, SUBSECTION NC (CLASS 2), 2007 EDITION, NO ADDENDA, & CODE CASE N-62-7.
 - B. DESIGN SPECIFICATION B-PES-0000688506 REV. 001
 - C. SEISMIC QUALIFICATION PER B-SPEC-01370-00001 REV. 001, DBE CAT-B
2. VALVE: 3/4" CLASS 900 LIMITED, SCH 160, 0.38" BORE
3. TYPE: BALL VALVE, METAL SEATED
4. OPERATOR: HANDWHEEL-OPEN COUNTER CLOCKWISE/CLOSE CLOCKWISE W/ POSILATCH
5. Cv: 4.5
6. PRESSURE RATING: 2031 psig @ 220° F
7. DESIGN PRESSURE: 1900 psig
8. DESIGN TEMPERATURE: 220° F
9. MINIMUM WALL THICKNESS PER ASME B16.34(3/8" BORE): 0.15"
10. TORQUE TO OPERATE: 250 in. lbs.
11. CAT ID #: 0000688506
12. CRN #: TBD
13. APPROX. WEIGHT: VALVE - 7lbs.
HANDWHEEL - 3 lbs.
TOTAL - 10 lbs.



DETAIL C
SCALE 4:1

GASKET DETAIL D
SCALE 4:1

CODE:
N2 = CODE
SN = SAFETY RELATED
CN = COMMERCIAL

ITEM	PART NUMBER	MATERIALS	DESCRIPTION	QTY.	CODE
1	B03W2XAV-211ZZ1N2-B01	SA-182 Gr. F316	BODY	1	N2
2	E03W2XAV-211Z1N2-B01	SA-182 Gr. F316 / RAM31	END CAP	1	N2
3	Y03X2AVV-231Z1N2-001	SA-182 Gr. F8a / RAM31	BALL	1	N2
4	U031VMVZ-211Z1CN-001	SA-182 Gr. F316 / RAM31	UPSTREAM SEAT	1	CN
5	MB03AVZZ-MA1ZZ1CN-001	SB-637 ALLOY UNS N07718	BELLEVILLE SPRING	1	CN
6	C03AVVZZ-712K01CN-001	17-4 / PT24	BODY SEAL	1	CN
7	S03004VV-911Z118N-B01	SA-838 860 TYP.1 / RAM31	STEM	1	CN
8	G03004AV-211KA1SN-001	SA-182 Gr. F316	GLAND	1	SN
9	MFSS004-012-V31SN-000	SA-193 Gr. B8M	STUD	4	SN
10	MFNS-004-W31Z18N-000	SA-194 Gr. 8M	NUT	4	SN
11	MGS-00500-038-242-CN1	SA-182 Gr. 302	GLAND SPRING	24	CN
12	MFSS008-014-V31N2-000	SA-193 Gr. B8M	STUD	4	N2
13	MFNS-008-W31Z1N2-000	SA-194 Gr. 8M	NUT	4	N2
14	MSP00A00806-RG1CN-001	GRAFOIL	GLAND PACKING	1	CN
15	MSP00A00806-RG1CN-001	SA-182 Gr. 316	GLAND PACKING	2	CN
16	MD03AVVZ-112ZZ1CN-001	SA-29 Gr. 4130 (H.T.)	DRIVE SLEEVE	1	CN
17	MS03-X2V-0B1Z1CN-001	SA-218 WCB	YOKE PLATE	1	CN
18	MT03VVZZ-0A1KA1CN-001	SA-29 Gr. 1020	THRUST BEARING	1	CN
19	MFCC004-014-V16CN-000	SA-574	CAP SCREW	4	CN
20	MHO-03XV-0A1Z1CN-002	SA-29 Gr. 1020	OVAL HANDWHEEL	1	CN
21	MM-03-LPZZ-2X100-001	STAINLESS STEEL	POSILATCH	1	CN
22	MFWF-E00FLT-W15CN-002	CARBON STEEL	FLAT WASHER	1	CN
23	MFCC000-020-V16CN-000	SA-574	CAP SCREW	1	CN
24	MTAG-NSAENV-2X100-001	STAINLESS STEEL	STANDARD N TAG	1	CN
25	MTAG-AAENV-2X100-002	STAINLESS STEEL	STANDARD TAG	1	CN

VALVTECHNOLOGIES, INC. HOUSTON, TX

SIZE 3/4" MODEL# V72R-BW-ST-W007-001N2-002






ANSI PRESSURE CLASS 900#

BODY SA-182 F316 TRIM 2R001

CERTIFIED BY:
VALVTECHNOLOGIES

SERIAL NO: XXXXXXXXXX

ANSI CL: 900#



ITEM #	ITEM	SIZE	TORQUE
9	GLAND PACKING	1/4-20 UNC X 1.25" LONG	2.5 ft./lbs.
12	BODY	3/8-24UNC X 1.50" LONG	10 ft./lbs.
19	STOP PLATE	1/4-20UNC X 1.50" LONG	10 ft./lbs.
23	HANDWHEEL	#10-24UNC X 2.00" LONG	2 ft./lbs.

REV	DATE	DESCRIPTION	ECN	BY	CHK	APR
2	11/16/12	REVISED PER CUSTOMER COMMENTS	04	DS	DS	CM
1	10/22/12	REVISED PER CUSTOMER MARKUPS	01	BS	DS	CM
0	09/05/12	INITIAL RELEASE		BS	DS	CM

VALVTECHNOLOGIES

5900 BRISLE ROAD, HOUSTON TEXAS 77002
 PH: (713) 800-0400 FAX: (713) 800-0439

V72R-BW-ST-W007-001N2-002
 ANSI 900#, WITH OVAL HANDWHEEL

121551-001

VALVES FOR USE IN NUCLEAR SYSTEMS		B-SPEC-04940-00004	Page 1 of 49
REV 001	UNITS ALL	COVER PAGE	

BrucePower™




TECHNICAL SPECIFICATION

VALVES FOR USE IN NUCLEAR SYSTEMS

B-SPEC-04940-00004



UNITS - ALL

Prepared by/Revised by:  Mike Séguin CNUS, Division of Canatom NPM	Verified by:  M. Jansen P Eng. CNUS, Division of Canatom NPM	Approved by:  J. Slawson P Eng. Senior Technical Engineer/Officer
Date: 2004-11-22	Date: 2004/11/23	Date: 2004-12-20

SEISMIC QUALIFICATION OF MECHANICAL EQUIPMENT		B - SPÉC - 01370-00001	Page 1 of 8
REV - 001	UNITS ALL		



TECHNICAL SPECIFICATION

B-SPEC-01370-00001

SEISMIC QUALIFICATION OF MECHANICAL EQUIPMENT

UNITS ALL



Revised by: R. Hamilton, P.Eng. CPUS 	Verified by: M.J. Jansen, P.Eng. CPUS 	Approved by: D.J. Armchuk, P.Eng. Bruce Power
Date: 2005/05/02	Date: 2005/05/02	Date: 5 May 2005

BRUCE A and BRUCE B VALVE SPECIFICATION SHEET



Rev: 001 Project: Bruce A and Bruce B

File: Cat ID: 688506
 Spec. Sheet: B-PES-0000688506
 Drawing No.: NK21-DRAW-33310-10011
 Drawing No.: NK29-DRAW-33310-10006
 Maint. Man.: B-MMM-33310-10003

General			
1	Description:	VALVE, BALL, 3/4", Nuclear CL 2, ASME/ANSI Class 900+, BW, SS, Manual, SCH160	CRN: Required*
2	Program:	Bruce NK21 and NK29	Units: See Table 1
3	Code:	ASME Section III, DIV. 1	Eff. Date: 2007 Edition: Nuclear Class 2 per CSA N285.0-08
4	QA Standard:	CSA Z299.2 or Equivalent *	Date: 1985 *
5	Technical Specification:	B-SPEC-04940-00004, Rev 001	
6	Manufacturer:	TBD	
Body			
7	Type:	Ball	Nominal size: 3/4" Port Size: *
8	Material:	SA-182 Gr. F316 or F316L (See Note 4)*	Connecting Pipe material: SA 312 TP 304L
9	End Connections:	Butt welded to 3/4", SCH 180 pipe	Rating: ASME/ANSI CL 900+(Interpolated) (See Note 8)
Bonnet			
10	B/B Joint Type:	See Note 3	Handwheel/Lever: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (See Note 6)
11	Material:	Same as Body	Live loading: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
12	Gasket:	*	Bellows Seal: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
13	Stem Packing:	Graphite to Supplier's Std. Mtl per B-SPEC-04940-00001, Rev. 001 *	Packing Blowout: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
14	Packing Leak-off:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Seal Weld: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Trim			
15	Seat Material:	Metal* (See Note 11) Hard faced	Disc Material: Ball SS (See Note 11) Hard faced
16	Disc Form:	Ball	Gulding: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
17	Back Seat:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Minimum Required C _v : Actual C _v : *
18	Trim Characteristic:	See Note 3.	Flow to: <input type="checkbox"/> Open <input type="checkbox"/> Close
Actuator			
19	Type:	Manual	
20	Operating Supply:		
21	Supply Failure Position:	<input type="checkbox"/> Open <input type="checkbox"/> Closed <input type="checkbox"/> As Is	
22	Limit Switch for Valve:	<input type="checkbox"/> Open Qty <input type="checkbox"/> Closed Qty	Ext. Switches Valve Open Qty:
23	Torque Switches Actuated When Valve	<input type="checkbox"/> Opens <input type="checkbox"/> Closes	Ext. Switches Valve Closed Qty:
Auxiliary			
24	Stem Position Indication By:	Pointer and scale <input checked="" type="checkbox"/> Open <input checked="" type="checkbox"/> Closed	
25	Disc Position Indication By:	<input type="checkbox"/> Open <input type="checkbox"/> Closed	
26	Description:		
Service Conditions			
27	Line Fluid:	D2O (D2O Specific gravity at 80 °F: 1.106)	
28	Design Pressure:	1900 psig (See Note 8)	Design Temperature: 220°F (See Note 8)
29	Shutoff Pressure Differential:	1900 psid (See Note 8)	To Stroke Open/Closed at: 1900 psid (See Note 8)
Tests (See Note 9)			
30	Hydrostatic Shell:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Seat Leakage: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
31	Gas Leak: Helium	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Seat He Test: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
32	Lowest System Temperature (Ref. Charpy Impact Test):	N/A	
Miscellaneous			
33	Seismic Specification:	B-SPEC-01370-00001 R001 (See Note 10)	Seismic Category: DBE <input type="checkbox"/> A <input checked="" type="checkbox"/> B <input type="checkbox"/> C
34	Seismicity: Site Acceleration (g) Level	<input type="checkbox"/> Low <input type="checkbox"/> Med	
35	Seismic Support Category:	<input type="checkbox"/> Rigid <input type="checkbox"/> Semi-rigid <input type="checkbox"/> Flexible	
36	Seismic Qual. Tests:	<input checked="" type="checkbox"/> Static OR <input checked="" type="checkbox"/> Dynamic OR <input checked="" type="checkbox"/> Seismic Analysis (See Note 10)	
37	If Dynamic:	<input type="checkbox"/> Valve Operates During Earthquake <input type="checkbox"/> Valve Operates After Earthquake	
38	If Dynamic:	<input type="checkbox"/> Normally Closed Valve (Test to Open) <input type="checkbox"/> Normally Open Valve (Test to Close)	
39	Design Report:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
40	Environment Radiation: 0.1 Mrad (gamma) /30 years (Note 12)	Environment Temperature: 27 °C (Note 12)	
41	Inaugural Inspection:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Environmental Qualification: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No



Prepared by: C. Graham	Reviewed by: K. Robertson	Verified by: A. Choudhry	Approved by: J. Stawson
Date: 14 JUN 2012	Date: 14 JUN 2012	Date: 14 JUN 2012	Date: 22 JUN 2012

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 1
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			

John Reich

Bruce Power

ACCEPTED

NOT ACCEPTED

ACCEPTED AS NOTED
RESUBMITTAL
REQUIRED

ACCEPTED AS NOTED
NO RESUBMITTAL
REQUIRED

Date *10 APR 2013*

Alton Reich
Signed

ACCEPTANCE OF THIS
DOCUMENT DOES NOT
RELIEVE THE CONTRACTOR
OF RESPONSIBILITY FOR ANY
ERRORS OR OMISSIONS

**ASME Code and Seismic Qualification of Bruce A&B Drain Valves –
VALVTechnologies 3/4" - 900# Model V72R-BW-ST-W007-001N2-002**

Prepared
For
VALVTechnologies

Bruce Power P.O. No: 00176474

VTI P.O. No: 074949
SO#121551

Alton Reich *Alton Reich*
Prepared By: _____

10 April 2013
Date

Jason Moon *Jason Moon*
Checked / Reviewed By: _____

4/10/2013
Date

Cesar Mejia *Cesar Mejia*
Approved By: _____

4/10/2013
Date





Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 1
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			

**ASME Code and Seismic Qualification of Bruce A&B Drain Valves –
VALVTechnologies 3/4" - 900# Model V72R-BW-ST-W007-001N2-002**

Prepared
For
VALVTechnologies

Bruce Power P.O. No: 00176474

VTI P.O. No: 074949
SO#121551

Alton Reich Prepared By: 	10 April 2013 Date
Jason Moon Checked / Reviewed By: 	4/10/2013 Date
Cesar Mejia Approved By: 	4/11/2013 Date

ASME-RPE Certification Page is Required: N

Controlled Computer Program Log Page is Required: N

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 2
------------------------------------	---------------	------------------------------	-----------

Customer: VALVTechnologies

Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves

PE CERTIFICATION

I, the undersigned, being a Registered Professional Engineer competent in the applicable field of design and using the certified Design Specification and the drawings identified below as a basis for design, do hereby certify that to the best of my knowledge and belief the Design Report is complete and accurate and complies with the design requirements of the ASME Boiler and Pressure Vessel Code, Section III, Division 1, 2007 Edition.

Design Specification and Revision: Bruce Power Company technical design specification B-SPEC-01370-00001, "Seismic Qualification of Mechanical Equipment", Rev. 001.

Drawings and Revision: See referenced valve drawings in Section 2.0

Design Report and Revision: 19228-001-QC-02, Revision 2.



Avi Shelcoviz

June 7, 2013
Date

419 67 019
Registration Number





Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 3
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			

REVISION SUMMARY SHEET

Rev.	Summary
0	Initial Issue
1	Incorporated Bruce Power comments (CAT ID 0000688506) and minor editorial comments from ValvTechnologies. Revised Pages: 1, 2, 3, 4, 6, 7, 15, 16, A3 Added Pages: 2, 19,20 Replaced Pages: None Voided / Deleted Pages: None
2	Incorporated comments from Bruce Power (CAT ID 688506, AR # 28301414-07). Revised Pages: 1 through 6, 10, 11, 15 through 17, 20 Added Page: 21 Replaced Pages: None Voided / Deleted Pages: None

RECORD OF REVISION

Rev. Level	Prepared By	Date	Checked by	Date	Approval	Date
0	Alton Reich	10-9-12	Jason Moon	10-16-12	Mahesh Patel	10-16-12
1	Alton Reich	12-9-12	Jason Moon	12-11-12	Mahesh Patel	12-13-12
2	Alton Reich	4-5-12	Jason Moon	4-10-12	Cesar Mejia	4/11/13



Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 4
------------------------------------	---------------	------------------------------	-----------

Customer: VALVTechnologies

Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves

TABLE OF CONTENTS

<u>Sections</u>	<u>Description</u>	<u>Page</u>
1.0	Purpose	5
2.0	Specifications / References / Design Inputs	5
3.0	Assumptions	6
4.0	Method of Analysis	6
5.0	Evaluation / Calculation	9
6.0	Summary / Conclusion	20

Total pages: 20

Attachments:

Attachment A	Design Verification Review Checklist	A1- A3
Attachment B	Email with Valve Component Information	B1- B2

Total attachment pages: 5

Appendices:

Appendix 01	Valve Drawings	(5 Total)
-------------	----------------------	-----------

Total appendix pages: 5

Total calculation pages including attachments and appendices: 30

Document Number	Revision	Project Number	Page
19228-001-QC-02	2	19228.0001	5
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			
<p>1.0 PURPOSE</p> <p>The purpose of this analysis is to verify the structural adequacy of the VALVTechnologies 3/4" 900#-class metal seated ball valve with oval handwheel (shown on VALVTechnologies drawing 121551 (V72R-BW-ST-007-001N2-002) [2.1]) per the requirements of valve specification sheet B-PES-0000688506 [2.3], and for the seismic loads specified in Bruce Power Company design specification B-SPEC-01370-00001 [2.2].</p>			
<p>2.0 SPECIFICATIONS / REFERENCES / DESIGN INPUTS</p> <p>2.1 VALVTechnologies, Drawing 121551, "V72R-BW-ST-W007-001N2-002 - ANSI 900# with Oval Handwheel", Rev 2.</p> <p>2.2 Bruce Power Company technical design specification B-SPEC-01370-00001, "Seismic Qualification of Mechanical Equipment", Rev. 001.</p> <p>2.3 Bruce A and Bruce B Valve specification sheet B-PES-0000688506.</p> <p>2.4 ValvTechnologies, Drawing MHO-03XV-CNW1, 3/8" Oval Handwheel w/ Lockout Device Commercial Nuclear (Welding), Rev. 1.</p> <p>2.5 ValvTechnologies, Drawing E03W2XAV-N2B1, 3/8" Endcap 900#-3100# with 3/4" SCH 160 BW Prep for Nuclear Class Use, Rev. 1.</p> <p>2.6 VALVTechnologies, Drawing B03W2XAV-N2B1, 3/8" Body 900#-3100# with 3/4" SCH 160 BW Prep for Nuclear Class Use, Rev. 1.</p> <p>2.7 Crane Technical Paper 410, "Flow of Fluids Through Valves, Fittings, and Pipe", 11/2009 printing.</p> <p>2.8 ASME Section II, 2007 Edition.</p> <p>2.9 Mark's Standard Handbook for Mechanical Engineers, 11th edition.</p> <p>2.10 Lindeburg, M., Mechanical Engineering Reference Manual, 9th edition.</p> <p>2.11 VALVTechnologies, Drawing S03004VV-911KA1SN-B01</p> <p>2.12 US NRC Reg Guide 1.92, "Combining Modal Responses and Spatial Components in Seismic Response Analysis", Rev. 2.</p> <p>2.13 American Institute of Steel Construction, Load and Resistance Factor Design, 2nd Edition.</p> <p>2.14 Beer, F. and Johnson, E., Mechanics of Materials, 1981.</p> <p>2.15 ASME Section III, 2007 Edition.</p> <p>2.16 ASME B16.34a, 1998 Edition, Valves – Flanged, Threaded and Welding End.</p> <p>2.17 Young, W., et. al., Roark's Formulas for Stress and Strain, 8th Edition.</p> <p>2.18 ASME Code Case N-62-7, Internal and External Valve Items, Section III, Division 1, Classes 1, 2, and 3.</p> <p>2.19 CAN3 N289.3, Design Procedures for Seismic Qualification of CANDU Nuclear Power Plants.</p>			

1

1

2

Document Number	Revision	Project Number	Page
19228-001-QC-02	2	19228.0001	6
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			
<p>3.0 ASSUMPTIONS</p> <p>3.1 The connecting pipe was assumed to be SA-312, TP304L, Schedule 160.</p> <p>3.2 Minor conservative assumptions are described within the calculations.</p> <p>4.0 METHOD OF ANALYSIS</p> <p>The VALVTechnologies ball valve under consideration is required to comply with ASME Section III Class 2 (NC), 2007 Edition [2.15] which references ASME B16.34a, 1998 Edition [2.16], and the plant-specific seismic requirements [2.2] which reference the CANDU seismic qualification procedures in CAN3-N289.3 [2.19].</p> <p>ASME Section III, subsection NC-3500 provides the rules related to valve design. Specifically, NC-3513 Alternative Design Rules for Special Class valves are used, since Limited Class valves are a subset of Special Class valves. This dictates compliance with the wall thickness requirements of ANSI B16.34.</p> <p>In accordance with NC-3521(c), if the valve assembly consists of extended parts attached to the valve body and/or end cap, an analysis should be performed based on static forces resulting from equivalent earthquake accelerations acting at the center of gravity of the extended mass. The ball valve evaluated in this calculation has extended part structures. The extended mass consists of the yoke post and hand wheel assembly. In the seismic response calculations, the entire extended part mass is considered to be concentrated at its center of gravity.</p> <p>Also, if the fundamental (lowest) natural frequency of the valve is calculated and is shown to be greater than the rigid frequency of 33 Hz, the valve is considered rigid and the required accelerations will be applied to the valve's lumped mass without multi-modal amplifications. The seismic adequacy of the valve is established using analytical methods. The seismic integrity of various portions will be demonstrated using classical engineering analysis techniques.</p> <p>The following are the design requirements for valve assemblies:</p> <ul style="list-style-type: none"> • The pipe system and not the valve shall be the limiting factor in the designing. The valve body will be demonstrated to be adequate to withstand piping end loads by meeting the following conditions: <ul style="list-style-type: none"> ○ The section modulus and area at a plane normal to the flow passage through the region of the body crotch shall be at least 110% of that for the piping connected to the valve body inlet and outlet nozzles. ○ The allowable stress for valve body material shall be equal to or greater than the allowable stress of the connecting pipe material at the pipe temperature. If this is not the case, then the body section modulus and area shall be reduced by the ratio of allowable body stress divided by the allowable piping material stress. • The valve body shall satisfy the minimum wall requirements of ASME B16.34a 1998 Edition. • The valve must be operable during and after a seismic event. This criteria will be met by demonstrating that the valve stresses are below the applicable allowable under seismic loading. • The valve extended parts shall meet the following requirements: <ul style="list-style-type: none"> ○ The natural frequency of vibration of the valve extended parts for all valve assemblies shall be greater than 33 Hz. 			

1

2

2

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 7
------------------------------------	---------------	------------------------------	-----------

Customer: VALVTechnologies

Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves

- The valve extended parts shall withstand the operating loads and a Required Response Spectrum load consisting of a ZPA acceleration of 2.16g's horizontal (each of two axes) and 2.75g's vertical (1.75g +1g gravity), applied simultaneously per the seismic specification [2.2]. When the equivalent static load method is used, the seismic load will be found by multiplying by a factor of 1.5 per CAN3-N289.3 [2.19].

The following evaluations are performed in this calculation to ensure Code compliance:

- Computation of valve body minimum wall thickness and comparison to the required thickness.
- Comparison of valve body wall area and section modulus vs. connecting pipe wall thickness.
- Computation of valve natural frequency
- Seismic evaluations
 - Evaluation of connections
 - Stress evaluation

These calculations are provided in Section 5 of this report.




Figure 1: Overview of the 3/4" 900# Metal Seated Ball Valve with handwheel. [2.1]

4.1 Design Input Information

The following is a general description of the valve: a 3/4" ball valve Nuclear Class 2 (NC), ASME/ANSI Class 900 Limited, butt welded, stainless steel, manually operated, for SCH 160 piping. The material of the body is SA-182 Gr. F316. The connecting pipe material is SA 312 TP 304L and the end connections are butt welded to the 3/4", SCH 160 pipe. Design conditions are as follows: the design pressure is

Document Number	Revision	Project Number	Page
19228-001-QC-02	2	19228.0001	8
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			
<p>1900 psig and the design temperature is to 220°F. The valve design details are provided in the manufacturer drawings, References [2.1, 2.4-2.6]</p> <p>4.2 Design Criteria</p> <p>The design criteria are provided in the Bruce specification [2.2].</p> <ul style="list-style-type: none">• Horizontal acceleration: 2.16g• Vertical acceleration: 1.75g (Not including acceleration due to gravity.)• A multiplier of 1.5 will be used when calculating the static load when the equivalent static load method is used.• The valve must be qualified to withstand the acceleration applied simultaneously in each of three directions.• The valve shall be considered in the worst possible orientation.• The mass of the valve, operator, and other appurtenances shall be considered in the seismic analysis.• The valve shall be designed to have a minimum natural frequency that is greater than 33 Hz so that it may be considered rigid and a static seismic analysis can be performed.• The valve shall be operable during and after a seismic event.			

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 9
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			

5.0 EVALUATION / CALCULATION

The valve is qualified based on the requirements of the ASME Code and the plant seismic specification.

5.1 Minimum Wall Thickness

The valve body is analyzed to ensure that it conforms to the requirements of ASME Code, Section III, Sub-article NC-3500 that refers to ASME B16.34 in NC-3513. The analysis presented below shows that the valve body satisfies the minimum wall requirements for an SA-182, F316, 900 lb Class Limited Valve.

Per Section 6.1.2 of ASME B16.34 [2.16] the inside diameter used for the purpose of determining the minimum wall thickness is the greater of the minimum diameter of the flow passage or 90% of the valve inside diameter at the end. For this valve the minimum diameter of the flow passage is 0.38", and 90% of the valve inside diameter at the end is: $0.90 * 0.61" = 0.55"$ Therefore, an inside diameter of 0.55" is used for determining the minimum wall thickness. The minimum wall thickness required per Table 3-B of B16.34 for a 3/4" diameter, 900 lb Class valve with an inside diameter of 0.56" is as follows:


$$t_m = 0.18 \text{ inch}$$

A minimum thickness of $0.77 * t_m$ is required at a distance of $1.33 * t_m$ from each end of the valve body per Para 6.1.5 and 6.2.1.

$$1.33 * t_m = 0.239 \text{ inch}$$

$$0.77 * t_m = 0.139 \text{ inch}$$

The actual wall thickness is provided on the valve drawing [2.1]:



$$t_{body} = 0.18 \text{ inch} = t_m = 0.18 \text{ inch}$$

Since the valve body thickness meets or exceeds the minimum required thickness it meets the Code requirements and is acceptable.

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 10
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			

5.2 Properties of Valve Body

The material properties of valve 121551-001 are SA-182 316. This evaluation considers the valve cross sectional area and section modulus in the crotch region in comparison to the connecting pipe properties.

$$S_{body} := 20000 \text{ psi} \quad \text{Allowable stress limits for SA-182 at } 300^{\circ}\text{F}$$

$$d_{ODb} := 1.050 \text{ inch}$$

$$d_{IDb} := 0.38 \text{ inch}$$

$$A_{body} := \frac{\pi * (d_{ODb}^2 - d_{IDb}^2)}{4} = 0.752 \text{ inch}^2 \quad \text{Area of Valve Body}$$

$$Z_{body} := \frac{\pi * (d_{ODb}^4 - d_{IDb}^4)}{32 * d_{ODb}} = 0.112 \text{ inch}^3 \quad \text{Section Modulus}$$

5.2.1 Properties of Pipe

Material of Pipe is SA-312 TP 304L, Pipe Size ¾ inch.

$$S_{pipe} := 16700 \text{ psi} \quad \text{Allowable Stress Limits for SA-312 TP304L}$$

$$d_{ODp} := 1.05 \text{ inch}$$

$$d_{IDp} := 0.612 \text{ inch}$$

$$A_{pipe} := \frac{\pi * (d_{ODp}^2 - d_{IDp}^2)}{4} = 0.572 \text{ inch}^2 \quad \text{Area of Pipe}$$

$$Z_{pipe} := \frac{\pi * (d_{ODp}^4 - d_{IDp}^4)}{32 * d_{ODp}} = 0.101 \text{ inch}^3 \quad \text{Section Modulus of Pipe}$$

5.2.2 Comparison of Properties of Pipe to Valve Body in the Crotch Region

$$\frac{A_{body}}{A_{pipe}} = 1.316$$

$$\frac{Z_{body}}{Z_{pipe}} = 1.111$$

$$S_{body} = 20,000.000 \text{ psi}$$

$$S_{pipe} = 16,700.000 \text{ psi}$$

$$S_{body} > S_{pipe} = \text{true}$$

No reduction required due to material strength. The valve body area and section modulus satisfy the requirements.

5.3 Piping Loads

Seismic qualification of the valve is performed to verify the valve assembly will operate maintain its structural integrity during a seismic event. The qualification method is by static analysis. This method is

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 11
------------------------------------	---------------	------------------------------	------------

Customer: VALVTechnologies

Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves

acceptable since the valve assembly is rigid as demonstrated in Section 5.4. Component adequacy is verified by comparing the maximum seismic stress with the appropriate allowable stress. The valve is intended to operate during and after a design seismic event.

The following structures of the valve assembly are analyzed:

- Handwheel
- Valve Body
- Stem
- Ball

The weight of each individual valve assembly component is listed below:

- Valve: 7 lbf
- Hand-wheel: 3 lbf
- Total valve assembly weight: 10 lbf

The valve is qualified by:

- Ensuring that it is capable of withstanding any applied piping loads.
- Ensuring that the valve natural frequencies are in the rigid range, which allows a static seismic analysis using the ZPA acceleration to be used.
- Performing the static seismic analysis.

5.4 Dynamic Analysis

The following dynamic analysis is performed to show that the valve assembly is rigid (natural frequencies > 33Hz [2.2]). The sections of the valve with the lowest natural frequencies are analyzed (the valve body and the valve stem) [2.10].

5.4.1 Valve Body

The valve body is conservatively evaluated to support the entire weight of the valve, gearbox and remote valve operator. The valve body is conservatively modeled as a pipe with fixed ends with the entire valve assembly weight focused at the center of the pipe. The minimum valve area and moment of inertia of the valve body occurs at the location of the valve adjacent to the end flanges. This area is used as the pipe cross-sectional area for the entire length of the valve for simplicity and conservatism.

5.4.1.1 Natural Frequency Due to Flexure:

The natural frequency of the valve body due to flexure is calculated based on treating it as a cantilever beam with a constant, hollow circular cross section, with the entire valve mass concentrated at the free end. The natural frequency is calculated using Case 3a in Table 16.1 of Roark's [2.17].

Inputs:

$W_v := 10 \text{ lbf}$	total valve weight
$E := 2.8 * 10^7 \text{ psi}$	modulus of elasticity for stainless steel
$OD_v := d_{ODe} = 0.975 \text{ inch}$	valve outer diameter (using low end tolerance is conservative)
$ID_v := d_{IDe} = 0.380 \text{ inch}$	valve inside diameter
$L_v := 5.5 \text{ inch}$	valve length

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 12
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			
<p>$g := 32.2 \text{ ft} / \text{s}^2$ acceleration of gravity</p> <p>Calculation:</p> <p>The valve moment of inertia is: $I_v := \frac{\pi}{64} (OD_v^4 - ID_v^4) = 0.043 \text{ inch}^4$</p> <p>The natural frequency is: $f_{nf} := \frac{1.732}{2\pi} \sqrt{\frac{EI_v g}{W_v L_v^3}} = 146.334 \text{ Hz}$</p> <p>Since $f_{nf} > 33 \text{ Hz} = \text{true}$ the valve can be treated as rigid for seismic analysis.</p> <p>5.4.1.2 <u>Natural Frequency Due to Torsion:</u></p> <p>The natural frequency of the valve body due to torsion is calculated using Case 8a in Table 16.1 of [2.17].</p> <p>Additional inputs:</p> <p>$m_v := 10 \text{ lb}$ Mass of the valve</p> <p>$d_{CG} := 0.63 \text{ inch}$ distance from valve centerline to the center of gravity</p> <p>$G := 1.1 * 10^7 \text{ psi}$ shear modulus for stainless steel</p> <p>Calculation:</p> <p>The torsional stiffness of the valve body is calculated using Case 10 of Table 10.1 of Roark's [2.17]:</p> <p>$K_v := \frac{\pi}{32} (OD_v^4 - ID_v^4) = 0.087 \text{ inch}^4$</p> <p>The mass moment of inertia of the valve is computed based on the outside and inside diameter, and the distance to the CG based on the parallel axis theorem:</p> <p>$J_v := m_v \left(\frac{(OD_v^2 + ID_v^2)}{8} + d_{CG}^2 \right) = 5.338 \text{ lbinch}^2$</p> <p>The torsional natural frequency is: $f_{nt} := \frac{1}{2\pi} \sqrt{\frac{GK_v}{J_v L_v}} = 563.558 \text{ Hz}$</p> <p>Since $f_{nt} > 33 \text{ Hz} = \text{true}$ the valve can be treated as rigid for seismic analysis.</p> <p>5.4.2 <u>Valve Stem</u></p> <p>The valve stem and sleeve assembly support the weight of the hand-wheel. Therefore, the valve stem and sleeve is analyzed for seismic loads. The valve stem and sleeve geometry is treated as a cylinder. The mass of the handwheel (3 lbm) is conservatively lumped at the top of the handwheel 7.25" above the centerline of the valve. The required shaft size for a natural frequency of 33Hz is calculated and then compared to the actual shaft size.</p>			

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 13
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			

5.4.2.1 Natural Frequency of Valve Stem Due to Flexure:

The valve stem and sleeve assembly support the weight of the hand-wheel. Therefore, the valve stem and sleeve is analyzed for seismic loads. The valve stem and sleeve geometry is treated as a cylinder. The mass of the handwheel (3 lb) is conservatively lumped at the top of the handwheel 7.25" above the centerline of the valve. The natural frequency is calculated using Case 3a in Table 16.8 of Roark's [2.17].

Inputs:

$W_h := 3\text{ lbf}$ handwheel weight
 $E := 2.8 \cdot 10^7 \text{ psi}$ modulus of elasticity for stainless steel
 $OD_s := 0.5\text{ inch}$ valve stem outside diameter (conservative)
 $L_s := 7.25\text{ inch}$ distance from the centerline of the valve from the top of the handwheel

Calculation:

The valve stem moment of inertia is: $I_s := \frac{\pi}{64} (OD_s^4) = 0.003 \text{ inch}^4$

The natural frequency is: $f_{ns} := \frac{1.732}{2\pi} \sqrt{\frac{EI_s g}{W_h L_s^3}} = 46.970 \text{ Hz}$

Since $f_{ns} > 33 \text{ Hz} = \text{true}$ the valve stem can be treated as rigid for seismic analysis.

5.5 Stem

The weight of the handwheel is 3 lbf. It is conservatively modeled that the seismic and gravitational loading of the handwheel is transmitted through the stem only. The analysis of the stem is conservative since it neglects the structural support of the yoke. The calculation is performed assuming the worst case installation configuration, which is upside down (gravity and the vertical seismic load acting in the same direction).

The figure below shows the cross-section of the stem. The worst case stress occurs at the location identified. Therefore only the stress at this location is calculated.




Figure 5.5.1 - Location of highest stem stress for worst case valve assembly configuration.

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 14
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			
<p>Nomenclature:</p> <p>$L_1 := 7.25inch$ (distance between centerline of valve and top of handwheel in the z direction)</p> <p>σ = stem tensile stress</p> <p>τ = stem shear stress</p> <p>$W_1 = 3.000 lbf$ weight of the handwheel</p> <p>$a_v := 2.75$ vertical acceleration, including gravity</p> <p>$a_h := 2.16$ horizontal acceleration</p> <p>$F_z := 1.5 * a_v * W_1 = 12.375 lbf$ vertical seismic loading (including static load factor)</p> <p>$F_x := 1.5 * a_h * W_1 = 9.720 lbf$ and $F_y := F_x = 9.720 lbf$ horizontal loading (including static load factor)</p> <p>M = moment created by force of interest</p> <p>$d_{stem} := 0.5inch$ stem diameter at the base</p> <p>$c := \frac{d_{stem}}{2}, c = 0.250 inch$, half of stem diameter</p> <p>V = shear force due to force of interest</p> <p>$Q := \frac{d_{stem}^3}{12}$, for circular cross-section [2.14]</p> <p>$I := \left(\frac{\pi}{64}\right) * d_{stem}^4 = 0.003 inch^4$, moment of inertia for circular cross-section</p> <p>$t := d_{stem}$, for circular cross-section</p> <p>T = torque due to force of interest</p> <p>$J := \frac{(\pi * d_{stem}^4)}{32} = 0.006 inch^4$, polar moment of inertia of valve stem</p> <p>Fundamental stress equations are used for analysis [2.14].</p> <p>Stress due to Fx:</p> <p>Tensile stress in the stem due to moment created by Fx:</p> <p>$\sigma_x = Mc/I$, therefore $\sigma_x := \frac{32 * F_x * L_1}{(\pi * d_{stem}^3)}, \sigma_x = 5,742.412 psi$</p> <p>Shear stress in stem due to force Fx:</p> <p>$\tau_x = VQ/IT, \tau_x := \frac{16 * F_x}{(3 * \pi * d_{stem}^2)}, \tau_x = 66.005 psi$</p> <p>Stresses due to Fy:</p> <p>The tensile stress due to the moment (at the location of interest) is zero.</p> <p>Shear stress in stem due to Fy:</p> <p>$\tau_y = VQ/IT$, therefore, $\tau_y := \frac{16 * F_y}{(3 * \pi * d_{stem}^2)}, \tau_y = 66.005 psi$</p>			

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 15
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			

$$\tau_y = VQ/IT, \text{ therefore, } \tau_y := \frac{16 * F_y}{(3 * \pi * d_{stem}^2)}, \tau_y = 66.005 \text{ psi}$$

Stresses due to Fz:

Tensile stress due to force Fz (includes gravity):

$$\sigma_z = Fz/A, \text{ therefore, } \sigma_z := \frac{4 * F_z}{(\pi * d_{stem}^2)}, \sigma_z = 63.025 \text{ psi}$$

Stress due to the valve operating torque:

$T_{OP} := 196inch * lbf$ valve operating torque at maximum allowable working pressure (per VALVTechnologies)

The shear stress due to the torque is:

$$\tau_{OP} := \frac{2T_{OP}}{\pi(d_{stem}/2)^3} = 7,985.758 \text{ psi}$$

The stresses within the valve stem are summarized in Table 2.

Table 2: Summary of Stem Stress

Force	Tensile Stress (σ)	Shear Stress (τ_x)	Shear Stress (τ_y)
Fx (seismic)	$\sigma_x = 5,742.412 \text{ psi}$	$\tau_x = 66.005 \text{ psi}$	0
Fy (seismic)	0	0	$\tau_y = 66.005 \text{ psi}$
Fz (seismic)	$\sigma_z = 63.025 \text{ psi}$	0	0
Fg (gravity)	Included in σ_z	0	0
T_{OP} (operating torque)		$\tau_{OP} = 7,985.758 \text{ psi}$	

The seismic stresses in the stem are combined using the SRSS method [2.12] and added to the stem stress due to gravity.

The total tensile stress is calculated from Table 2:

$$\sigma_{total} := \sqrt{(\sigma_x^2 + \sigma_z^2)}, \sigma_{total} = 5,742.758 \text{ psi}$$

The total shear is calculated from Table 2:

$$\tau_{total} := \sqrt{(\tau_x^2 + \tau_y^2 + \tau_{OP}^2)}, \tau_{total} = 7,986.304 \text{ psi}$$

Using Mohr's circle methodology, the maximum tensile and shear stress are calculated and compared to the allowable stress.

Document Number	Revision	Project Number	Page
19228-001-QC-02	2	19228.0001	16
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			
<p>The allowable tensile stress for the stem, SA-639 Grade 660, at a conservative temperature of 300°F is $\sigma_{allowable} := 37100 \text{ psi}$ [2.8]. The allowable shear stress is 40% of the allowable yield strength at the design temperature ($\tau_{allowable} := 0.4 * \sigma_{allowable} = 14,840.000 \text{ psi}$) [2.15, 2.13].</p> <p>Note: Using the design temperature is conservative since the location of maximum stress in the stem occurs several inches away from the wetted part of the valve.</p> <p>The maximum shear stress is calculated using its definition as the radius of Mohr's Circle:</p> $\tau_{max} := \sqrt{[0.5(\sigma_x - \sigma_z)]^2 + \tau_{total}^2} \quad \tau_{max} = 8,476.138 \text{ psi} < \tau_{allowable} = 14,840.000 \text{ psi} \quad \text{ACCEPTABLE}$ <p>Factor of safety, $FS_{\tau} := \frac{\tau_{allowable}}{\tau_{max}} = 1.751$</p> <p>The maximum principal stress is:</p> $\sigma_{max} := 0.5 * (\sigma_x + \sigma_z) + \tau_{max} \quad \sigma_{max} = 11,378.856 \text{ psi} < \sigma_{allowable} = 37,100.000 \text{ psi} \quad \text{ACCEPTABLE}$ <p>Factor of safety, $FS_{\sigma} := \frac{\sigma_{allowable}}{\sigma_{max}} = 3.260$</p> <p>5.6 Stem to Ball Connection</p> <p>Pressure loads on the ball are transmitted from the ball to the body. The loading on the stem to ball connection due to pressure is negligible. Since the ball and stem are supported by the valve body and operator, there is no significant seismic or pressure loading on the stem to ball connection. Based on the valve design, there is no credible failure mode of the stem to ball connection due to pressure or seismic loading.</p> <p>5.7 Ball</p> <p>The ball is lightweight, of robust geometry and is supported by the valve assembly. Therefore the seismic loads on the ball are negligible. The Service Level D loads on the ball are addressed in Section 5.9.</p> <p>5.8 Body Bolting</p> <p>The body bolts must meet the requirements of section 6.4.2.1 of B16.34 [2.16]. This specifies a minimum bolt tensile area in relation to the pressure area.</p> <p>$P_{class} := 900$ valve class</p> <p>$d_{IDb} = 0.380 \text{ inch}$ inside diameter exposed to pressure</p> <p>$A_{ID} := \frac{\pi d_{IDb}^2}{4} = 0.113 \text{ inch}^2$ inside area</p> <p>$A_{bolt} = 0.0678 \text{ inch}^2$ conservatively using the cross sectional area at the minor diameter</p> <p>$n_{bolt} := 4$ number of body bolts</p>			

2

2

2

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 17
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			
$A_{totalB} := n_{bolt} A_{bolt} = 0.271 \text{ inch}^2$ <p style="text-align: right;">total bolt area</p> $S_{bolt} := 15600 \text{ psi}$ <p style="text-align: right;">bolt allowable, conservatively taken at 300°F</p> $P_{class} \frac{A_{ID}}{A_{totalB}} = 376.366$ <p>Since $P_{class} \frac{A_{ID}}{A_{totalB}} < S_{bolt} 0.35 / \text{psi} = \text{true}$, the requirements of section 6.4.2.1 of B16.34 are met.</p> <p>The body bolting is checked due to the force that act to separate the halves of the valve. These are the pressure force on the ball when it is closed and the seismic force acting on the end cap. The bolting material is SA193 GR B8M.</p> <p><u>Pressure force:</u></p> $P_d := 1900 \text{ psi}$ <p style="text-align: right;">design pressure</p> $F_p := P_d A_{ID} = 215.482 \text{ lbf}$ <p style="text-align: right;">force due to the pressure</p> <p><u>Seismic force:</u></p> <p>The analysis is performed with the valve installed vertically so that the vertical seismic force acts in the same direction as gravity. The horizontal seismic force produces a shear load in the studs.</p> $W_{EC} := 1.04 \text{ lbf}$ <p style="text-align: right;">weight of the end cap</p> $F_{ECv} := 1.5 * \alpha_v * W_{EC} = 4.290 \text{ lbf}$ <p style="text-align: right;">vertical force (including static load factor)</p> $F_{EC_h} := 1.5 * \alpha_h * W_{EC} = 3.370 \text{ lbf}$ <p style="text-align: right;">horizontal force (including static load factor)</p> <p>The horizontal force will also produce a bending moment that will be reacted out as a force couple on the studs. Assuming that the entire mass of the end cap is lumped at the end, the moment at the attachment point is:</p> $L_{EC} := 2.5 \text{ inch}$ <p style="text-align: right;">length of the end cap [2.5]</p> $M_{EC} := F_{EC_h} * L_{EC} = 8.424 \text{ inch lbf}$ <p style="text-align: right;">moment due to horizontal acceleration</p> <p>The magnitude of the force couple is computed based on the distance between the studs. The studs are 90° apart on a 1.75" diameter bolt circle.</p> $d_{stud} := 1.75 \text{ inch} (\sin(45 \text{ deg})) = 1.237 \text{ inch}$ <p style="text-align: right;">distance between the studs</p> $F_{ECc} := \frac{M_{EC}}{d_{stud}} = 6.808 \text{ lbf}$ <p style="text-align: right;">tensile force on a stud due to the bending moment</p>			

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 18
------------------------------------	---------------	------------------------------	------------

Customer: VALVTechnologies

Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves

One stud will experience tensile force from acceleration in both horizontal directions. This will be added to the other tensile forces noted above.

The total tensile force is: $F_{Bl} := F_P + F_{ECv} + 2F_{ECc} = 233.387 \text{ lbf}$

$$\sigma_{boltT} := \frac{F_{Bl}}{n_{bolt} A_{bolt}} = 860.572 \text{ psi} \quad \text{bolt tensile stress}$$

$$\sigma_{boltS} := \frac{\sqrt{(2)} F_{ECc}}{n_{bolt} A_{bolt}} = 17.571 \text{ psi} \quad \text{bolt shear stress}$$

$$\sigma_{bolt} := \sqrt{\sigma_{boltT}^2 + \sigma_{boltS}^2} = 860.751 \text{ psi} \quad \text{total bolt stress}$$

The bolt stress is significantly less than the bolt allowable stress of 15,600 psi at 300°F.

5.9 Service Level D Loading

Note 8(c) of the valve specification, Reference 2.3, describes a Level D service condition with a pressure of 15,100 psia at a temperature of 302°F downstream of the valve. Under this condition, the valve is closed and not required to open, but must maintain pressure integrity.

For Level D Service Loadings NC-3521 of ASME Section III (Reference 2.15) refers to Table NC-3521-1. The table specifies that the membrane stress limit for Service Level D conditions is 2.0S, where S is the material allowable stress provided in ASME Section II (Reference 2.8) at the appropriate temperature. The ends of the valve can be treated as a pipe for the purpose of computing the required wall thickness for the Service Level D pressure. NC-3641.1 is used to check the thickness of the valve endcap (location of the minimum thickness):

$D_o := 0.980 \text{ inch}$ outside diameter (Reference 2.5)

$D_i := 0.614 \text{ inch}$ inside diameter (Reference 2.5)

$$t_a := \frac{(D_o - D_i)}{2} = 0.183 \text{ inch} \quad \text{actual wall thickness}$$

Since the wall thickness ratio, $\frac{D_o}{t_a} = 5.355$, is less than 6, equation 6 in NC-3641.1 is used to compute

the coefficient y:
$$y := \frac{D_i}{(D_i + D_o)} = 0.385$$

$P := 15100 \text{ psi}$ Service Level D pressure

$S := 20000 \text{ psi}$ Allowable stress for SA-182, F316 at 302°F

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 19
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			


$S_d := 2S = 40,000.000 \text{ psi}$ for Service Level D the allowable is twice the basic allowable per Table NC-3521-1

The required minimum wall thickness is computed using equation 3 in NC-3641.1:

$$t_m := \frac{PD_o}{2(S_d + Py)} = 0.161 \text{ inch}$$

Since the minimum actual wall thickness per the valve drawing (0.18 inch) is greater than the required minimum thickness, the valve meets the Service Level D requirements.

The valve ball is also checked for the Service Level D loading. The postulated failure mode of the ball, which is in the closed position, is a shear failure along the projected area of the endcap ID due to the high pressure acting on the surface of the ball. The area that the shear force would act on is calculated based on the outer diameter of the ball and the inner diameter of the endcap.



Shear surface area of the postulated failure for Service Level D pressure from the CAD model of the ball.

The surface area that the shear force acts upon is a cylinder with a diameter that matches the ID of the endcap as shown in the figure above. Conservatively, half of the area extracted from the CAD model is used.

$$A_{shear} := \frac{0.63 \text{ inch}^2}{2} = 0.315 \text{ inch}^2$$

The force due to the Service Level D pressure and the inside diameter of the endcap is:

$$ID_{ec} := 0.375 \text{ inch}$$

$$F_{SLD} := P \left(\frac{\pi ID_{ec}^2}{4} \right) = 1,667.744 \text{ lbf}$$

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page 20
------------------------------------	---------------	------------------------------	------------

Customer: VALVTechnologies

Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves

The shear stress due to this force is:

$$\sigma_{SLD} = \frac{F_{SLD}}{A_{shear}} = 5,294.425 \text{ psi}$$

Since this is less than the Service Level D allowable, $\sigma_{SLD} < S_d = \text{true}$, the ball will withstand the Service Level D loading.

6.0 SUMMARY / CONCLUSION

An ASME Code and seismic qualification of the 3/4" VALVTech ball valve has been performed for the Bruce A&B drain valve application. The results of this qualification are summarized below.

Item	Report Section	Actual Valve	Required / Limit Value	Notes
Valve body thickness	5.1	0.18"	0.18"	Requirement met
Valve cross sectional area vs. pipe	5.2	131%	110%	Requirement met
Valve section modulus vs. pipe	5.2	111%	110%	Requirement met
Valve body natural frequency	5.4	563.56 Hz	33 Hz	Allows static seismic analysis
Valve stem natural frequency	5.4	46.97 Hz	33 Hz	Ensures stem natural frequency > 33 Hz
Stem stress	5.5	11,379 psi	37,100 psi	Requirement met
Body bolts	5.8	861 psi	15,600 psi	Requirement met
Service level D – valve thickness	5.9	0.18"	0.16"	Requirement met
Service level D – ball stress	5.9	5,294 psi	40,000 psi	Requirement met

This analysis has demonstrated that the 3/4" ball valve [2.1] meets the ASME Code, Subsection NC, Class 2 requirements [2.15] and seismic requirements of the Bruce specification [2.2, 2.3]. Based on this analysis, the valve will be operable during and following a seismic event.

2

1

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page A1
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			

ATTACHMENT A

Design Verification Review Checklist

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page A2
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			

ATTACHMENT A
DESIGN VERIFICATION REVIEW CHECKLIST

Item	Criteria to Be Reviewed	Not Applicable	Reviewed and Accepted	Date
1a	Are the Design Inputs consistent with the Project Requirements?		√	4/10/12
1b	Have all Design Inputs been correctly incorporated into the calculation?		√	4/10/12
1c	Are the sources of all Design Inputs clearly and correctly identified?		√	4/10/12
2a	Have all assumptions been identified and described within the Assumptions Section?		√	4/10/12
2b	Have all assumptions been provided with sufficient basis for verification?		√	4/10/12
2c	Have all assumptions been verified, identified for re-verification, or otherwise justified?		√	4/10/12
3	Have all appropriate quality and quality assurance requirements been specified and satisfied within the bounds of the calculation?		√	4/10/12
4a	Are the applicable codes, standards, and regulatory requirements adequately referenced?		√	4/10/12
4b	Are the latest applicable revisions/issues/addenda/editions of all References used?		√	4/10/12
4c	Have all References been provided with sufficient detail to permit independent verification?		√	4/10/12
4d	Have all References been listed?		√	4/10/12
5	Have applicable design, construction and operating experience been considered?		√	4/10/12
6	Have design interface requirements been satisfied?		√	4/10/12
7a	Is the Method of Analysis appropriate and consistent with Project Criteria?		√	4/10/12
7b	Has the Method of Analysis been clearly described?		√	4/10/12
7c	Have all limitations associated with the Method of Analysis been identified?		√	4/10/12
8a	Is the Purpose clearly stated and consistent with Project requirements?		√	4/10/12
8b	Is the output/results reasonable when compared to the inputs?		√	4/10/12
8c	Is the calculation summary clear and understandable?		√	4/10/12
8d	Does the conclusion fully address and support the stated Purpose?		√	4/10/12
9	Are the specified parts, equipment and processes suitable for the required application?		√	4/10/12
10	Are the specified materials compatible with design requirements, environmental conditions and each other?		√	4/10/12
11a	Have adequate design features and accessibility been provided to perform inspection, maintenance and repair?	N/A		4/10/12
11b	Have adequate maintenance requirements and inspection requirements been identified?	N/A		4/10/12
12	Are accessibility and other design provisions adequate for performance of needed maintenance and repair?	N/A		4/10/12
13	Has adequate accessibility been provided to perform the inservice inspection expected to be required during plant life?	N/A		4/10/12

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page A3
------------------------------------	---------------	------------------------------	------------

Customer: VALVTechnologies



Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves

ATTACHMENT A
DESIGN VERIFICATION REVIEW CHECKLIST

Item	Criteria to Be Reviewed	Not Applicable	Reviewed and Accepted	Date
14	Has the design and installation properly considered all hazardous exposures to the public and plant personnel?	N/A		4/10/12
15	Are the acceptance criteria sufficient to allow verification that design requirements have been satisfactorily accomplished?		√	4/10/12
16	Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?	N/A		4/10/12
17	Are adequate handling, storage, cleaning and shipping requirements specified?	N/A		4/10/12
18	Are adequate identification requirements specified?		√	4/10/12
19a	Are requirements for record preparation, review, and approval properly identified on the document?		√	4/10/12
19b	Are requirements for record retention adequately specified?		√	4/10/12
20	Are all attachments identified and complete?		√	4/10/12

Item	Comments		

REVIEW AND ACCEPTANCE OF ABOVE CRITERIA

	PRINTED NAME	SIGNATURE	DATE
Checked / Reviewed By:	Jason Moon		4/10/2013
Engineering Approval By:	Cesar Mejia		4/11/2013



Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page B1
------------------------------------	---------------	------------------------------	------------

Customer: VALVTechnologies

Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves

ATTACHMENT B

Email with Valve Component Information



Document Number	Revision	Project Number	Page
19228-001-QC-02	2	19228.0001	B2
Customer: VALVTechnologies			
Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves			
<p>From: Daniel Schurman [mailto:dschurman@valv.com] Sent: Wednesday, September 26, 2012 11:45 AM To: Cesar Mejia; Patel, Mahesh Cc: Patel, Mahesh Subject: RE: Design and Seismic Report for Bruce Power</p> <p>Mahesh,</p> <p>See attached drawings for body, endcap, and handwheel.</p> <p>Body weighs 2.43 lbs Endcap weighs 1.04 lbs Handwheel weighs 2.19 lbs</p> <p>Material type is on the customer drawing Cesar submitted to you.</p> <p>C of G for assembly is on the drawing as well.</p> <p>Studs are standard SA-193 B8M 3/8-16 UNC x 1.75" end-to-end.</p> <p>Let me know if you have any other questions.</p> <p>Thanks, Dan</p>			

Document Number 19228-001-QC-02	Revision 2	Project Number 19228.0001	Page A1-1
------------------------------------	---------------	------------------------------	--------------


Customer: VALVTechnologies

Title: ASME Code and Seismic Qualification of Bruce A&B Drain Valves

Appendix 01

Valve Drawings (5 Total)

NOTES:
1. WELDING TO BE PER AWS D1.1




NOTE: PIN TO BE WELDED IN THE DOWN POSITION TO ENSURE PROPER FITMENT AND ABILITY TO ACTUATE.

RELEASED FOR MANUFACTURE		BILL OF MATERIALS		
APPROVED:	DATE:	ITEM	DESCRIPTION	QTY.
W/O#		1	MHO-03XV-CNN1	1
P.O.#		2	MM-03-LPZZ-2X1.00-001	1
S.O.#			LOCKING MECHANISM	1
J.O.#			VALVE TECHNOLOGIES	1
			3/8" OVAL HANDWHEEL	
			W/ LOCKOUT DEVICE	
			COMMERCIAL NUCLEAR (WELDING)	
			MHO-03XV-CNN1	1

REV	DATE	DESCRIPTION	ECN	BY	CHK	APR

PROPERTY	UNIT	DATE	VALUE
PROPERTY	INCHES	06/21/12	.03 MAX
PROPERTY	INCHES	06/21/12	.005
PROPERTY	INCHES	06/21/12	.010 T.I.R.
PROPERTY	INCHES	06/21/12	125 RMS
PROPERTY	INCHES	06/21/12	.015

ITEM	DESCRIPTION	QTY.
1	3/8" OVAL HANDWHEEL	1
2	LOCKING MECHANISM	1



RELEASED FOR MANUFACTURE APPROVED: _____ DATE: _____ W/O# : _____ MATERIAL : _____ P.O.# : _____ QUANTITY : _____ S.O.# : _____ J.O.# : _____						MODEL NAME: E03W2XAV-N2B1 DRAWN BY: ES CHECKED BY: DS APPROVED BY: DS		TITLE: 38" ENDCAP 9006-31006 WITH RENE 80 BSI REP. FOR NUCLEAR GLASS USE		E03W2XAV-N2B1 SH. OF 1	
DIMENSIONS ARE IN INCHES REMOVE BURRS AND BREAK EDGES UNLESS OTHERWISE SPECIFIED CORNER RADI: .03 MAX .005 ± .015 .0005 ± .005 CONCENTRICITY .010 T.I.R. SURFACE TEXTURE 125 RMS MIN INTERNAL FILLETS .015			REV DATE DESCRIPTION ECN BY CHK APR			PART NUMBER: 9006-31006 DATE: 08/28/12 WEIGHT: 0.0217 LB QUANTITY: 100 OPERATOR: DS DATE: 08/11/12 APPROVED BY: DS		VALVE TECHNOLOGIES 1875 SOUTH ROCKY HILL AVENUE, SUITE 100 ROCKY HILL, CT 06067-4300 PH: (860) 846-8000 FAX: (860) 846-8001 WWW.VTECH.COM		TYPE: 38" ENDCAP 9006-31006 WITH RENE 80 BSI REP. FOR NUCLEAR GLASS USE	

